



THIS DRAWING IS INTENDED TO BE PRINTED IN COLOR.



PLAN VIEW



SECTION A-A

NOTES:

1. MANUFACTURED TO ASTM C-913 (LATEST REVISION).
2. CONCRETE: 4,000 PSI AT 28 DAYS.
3. REINFORCING: #4 BAR @ 8" C.C. E.W. BOTH WAYS (GRADE 60).

PRODUCTION WORK ORDER		PRODUCT I.D.: CTS	DESCRIPTION: 96" X 96" X 8" SLAB		
	QUALITY CONTROL CHECKLIST	PRODUCT VIEW: RIGHT SIDE UP	CUSTOMER: STEWART RICHEY		
	☐ ALL DIMENSIONS CORRECT.	PLANT: BEAVER DAM, KY.	PROJECT: GOTTBRATH TRANSFORMER PAD		
	☐ LIFTERS INSTALLED.	WEIGHT: 5,540 LBS.	STRUCTURE: QL1		
	☐ HOLE LOCATION CORRECT.	TOP SECTION JOINT: N/A	QUOTE/SALES ORDER NO: 26-2541		
	☐ REINFORCING CORRECT.	BASE SECTION JOINT: N/A	PC: T. LEWIS		DRAWING: S. FELLETTTER
	☐ FINISH ON SLAB SURFACE UNIFORM.	QC CHECK INITIALS:	DATE: 06/11/26	SCALE: NTS	PG. 1 of 1
	☐ OUTSIDE TOP EDGE TROWELLED.				
☐ FLAT BOTTOM.					