

Plant: Beaver Dam

9/29/2026 2:19:01 PM

P1 **CVT**

ROOF - EASI-SET BUILDING - RP-03 - 145" x 216"

[illegible]

Plant: Beaver Dam

9/29/2026 2:19:01 PM

P1 **CVT**

ROOF - EASI-SET BUILDING - RP-03 - 145" x 216"

Roof Reinforcing View
SCALE: 1" = 1'-0"

SHOP NOTE:
DIMENSIONS PROVIDED ARE PULLED FROM EDGE OF CAGE TO CENTERLINE OF REBAR AND TO CENTER OF REBAR TO CENTER OF REBAR (EXCEPT PT CABLE LOCATION)

REINFORCING SCHEDULE

MARK #	DESCRIPTION	QTY
MK001	#3 x 5'-0"	4
MK002	#3 x 11'-11"	2
MK003	#3 x 17'-9"	2
MK004	#4 x 1'-6"	10

MESH SCHEDULE

MARK #	DESCRIPTION	QTY
SI	2" x 68'-4" LONG P.T. CABLE	1
MI	W4W4 4"x4" WW 17'-9" x 11'-11"	1

REINFORCING SCHEDULE

MARK #	DESCRIPTION	QTY
SI	2" x 68'-4" LONG P.T. CABLE	1
MI	W4W4 4"x4" WW 17'-9" x 11'-11"	1

REINFORCING SCHEDULE

MARK #	DESCRIPTION	QTY
SI	2" x 68'-4" LONG P.T. CABLE	1
MI	W4W4 4"x4" WW 17'-9" x 11'-11"	1

REINFORCING SCHEDULE

MARK #	DESCRIPTION	QTY
SI	2" x 68'-4" LONG P.T. CABLE	1
MI	W4W4 4"x4" WW 17'-9" x 11'-11"	1

REINFORCING SCHEDULE

MARK #	DESCRIPTION	QTY
SI	2" x 68'-4" LONG P.T. CABLE	1
MI	W4W4 4"x4" WW 17'-9" x 11'-11"	1

REINFORCING SCHEDULE

MARK #	DESCRIPTION	QTY
SI	2" x 68'-4" LONG P.T. CABLE	1
MI	W4W4 4"x4" WW 17'-9" x 11'-11"	1

REINFORCING SCHEDULE

MARK #	DESCRIPTION	QTY
SI	2" x 68'-4" LONG P.T. CABLE	1
MI	W4W4 4"x4" WW 17'-9" x 11'-11"	1

REINFORCING SCHEDULE

MARK #	DESCRIPTION	QTY
SI	2" x 68'-4" LONG P.T. CABLE	1
MI	W4W4 4"x4" WW 17'-9" x 11'-11"	1

REINFORCING SCHEDULE

MARK #	DESCRIPTION	QTY
SI	2" x 68'-4" LONG P.T. CABLE	1
MI	W4W4 4"x4" WW 17'-9" x 11'-11"	1

REINFORCING SCHEDULE

MARK #	DESCRIPTION	QTY
SI	2" x 68'-4" LONG P.T. CABLE	1
MI	W4W4 4"x4" WW 17'-9" x 11'-11"	1

REINFORCING SCHEDULE

MARK #	DESCRIPTION	QTY
SI	2" x 68'-4" LONG P.T. CABLE	1
MI	W4W4 4"x4" WW 17'-9" x 11'-11"	1

REINFORCING SCHEDULE

MARK #	DESCRIPTION	QTY
SI	2" x 68'-4" LONG P.T. CABLE	1
MI	W4W4 4"x4" WW 17'-9" x 11'-11"	1

REINFORCING SCHEDULE

MARK #	DESCRIPTION	QTY
SI	2" x 68'-4" LONG P.T. CABLE	1
MI	W4W4 4"x4" WW 17'-9" x 11'-11"	1

REINFORCING SCHEDULE

MARK #	DESCRIPTION	QTY
SI	2" x 68'-4" LONG P.T. CABLE	1
MI	W4W4 4"x4" WW 17'-9" x 11'-11"	1

REINFORCING SCHEDULE

MARK #	DESCRIPTION	QTY
SI	2" x 68'-4" LONG P.T. CABLE	1
MI	W4W4 4"x4" WW 17'-9" x 11'-11"	1

REINFORCING SCHEDULE

MARK #	DESCRIPTION	QTY
SI	2" x 68'-4" LONG P.T. CABLE	1
MI	W4W4 4"x4" WW 17'-9" x 11'-11"	1

REINFORCING SCHEDULE

MARK #	DESCRIPTION	QTY
SI	2" x 68'-4" LONG P.T. CABLE	1
MI	W4W4 4"x4" WW 17'-9" x 11'-11"	1

REINFORCING SCHEDULE

MARK #	DESCRIPTION	QTY
SI	2" x 68'-4" LONG P.T. CABLE	1
MI	W4W4 4"x4" WW 17'-9" x 11'-11"	1

REINFORCING SCHEDULE

MARK #	DESCRIPTION	QTY
SI	2" x 68'-4" LONG P.T. CABLE	1
MI	W4W4 4"x4" WW 17'-9" x 11'-11"	1

REINFORCING SCHEDULE

MARK #	DESCRIPTION	QTY
SI	2" x 68'-4" LONG P.T. CABLE	1
MI	W4W4 4"x4" WW 17'-9" x 11'-11"	1

REINFORCING SCHEDULE

MARK #	DESCRIPTION	QTY
SI	2" x 68'-4" LONG P.T. CABLE	1
MI	W4W4 4"x4" WW 17'-9" x 11'-11"	1

REINFORCING SCHEDULE

MARK #	DESCRIPTION	QTY
SI	2" x 68'-4" LONG P.T. CABLE	1
MI	W4W4 4"x4" WW 17'-9" x 11'-11"	1

REINFORCING SCHEDULE

MARK #	DESCRIPTION	QTY
SI	2" x 68'-4" LONG P.T. CABLE	1
MI	W4W4 4"x4" WW 17'-9" x 11'-11"	1

Job Name: 25-3470P9 CCHS Precast Building
Job Location: 5185 Fort Campbell BLVD
Contractor: Christian County Board of Education C/O A&K Construction

Plant: Beaver Dam
9/29/2026 2:19:01 PM

Tech: J. Coppage
PC: E. Bradley



Structure ID: RP-03 - Roof Panel 3

P1 CVT

ROOF - EASI-SET BUILDING - RP-03 - 145" x 216"



PT Check for Roof Panels RP-03/RP-04 (PCI MNL)

Material Data

(7) Wire lo-lax Strand - ASTM A416

Φ_{ps} 0.500 in,

A= 0.153 in²

E= 28500000 psi

fpu= 270 ksi

Strand Length 784 in


Assume (Info supplied by strand manufacturer)

k= 0.0007 Wobble Friction Coeff.

μ = 0.05 Curvature friction coeff. (Initial tension of 3,000 lbs)

Strand is to be stressed 70% of ultimate

= 28917 lbs



Cable Configuration

Adjustments to tensioning

1) Dead end anchor wedge seating loss

~ Expected to be 1/8 in

2) Live end anchor wedge seating loss

~ Expected to be 1/8 in, recommend over pull 1/8"

3) Elastic Shortening

Neglect for this pnl

4) Friction Loss

Additional force to overcome frictional forces between strand and sheathing

Tensioning Computations

$$\text{Basic Elongation} = \frac{(\text{Force required beyond initial tension}) (\text{Length of strand between anchorages})}{(\text{Area of strand}) (\text{Modulus of Elasticity})}$$
$$= 4.66 \text{ in}$$

Adjustments

a) Dead end anchor wedge seating: Add 1/8" to elong. No force adjustment req'd

Add 1/8 in

b) Live end seating: over pull by 1/8"

1/8 in

Force adjustment t = 695 lbs lbs $\alpha = \text{curvature} = \pi(2.5) = 7.85 \text{ radians}$

$$\text{c) Friction losses} \quad \frac{PD}{PS} = e^{-[kL + \mu\alpha]}$$

= 0.645

Avg. strand force = 0.823 17.75% Loss

Recommend sequential jacking at both ends of the tendon be used to reduce the overstressing the strand at the live end

Friction loss at mid-point of tendon

$$\frac{PD}{PS} = e^{-\frac{[kL + \mu\alpha]}{2}}$$

= 0.803

Avg. strand force over

half of tendon = 0.902 9.84% Loss

Total force and elongation at live end must be increased to compensate for friction losses

Elong. Adjustment = 0.459 in

Force Adjustment = 2846 lbs

Total Force Required = 32458 lbs **OK**

Elongation Summary:

Gross Theoretical Elongation			
Basic Elongation	4.66 in		
Dead End Seating Loss	0.125 in		
Live End Seating Loss	0.125 in		
Friction Losses	0.459 in		
Total Elongation	5.37 in		
Rounded	5 6/16 in		
Tolerance limits	-7.0%	4.99 in	5 in
	+7.0%	5.74 in	5 12/16 in