



**GENERAL NOTES:**

1. MANUFACTURED PER ASTM C-913 (LATEST REVISION)
2. CONCRETE: 5,000 PSI AT 28 DAYS
3. REINFORCEMENT - 2" MIN. REBAR CLEARANCE (TYP):  
 - FLAT LID: #5 BAR @ 6" C.C. E.W. (GRADE 60)  
 - DOGHOUSE RISER: #4 BAR @ 12" C.C. E.W. (GRADE 60)
4. WEIGHTS:  
 8" FLAT LID 3,655 LBS  
 54" DOGHOUSE RISER 9,655 LBS  
 TOTAL WEIGHT 13,310 LBS
5. CONTRACTOR TO VERIFY ALL DIMENSIONS BEFORE MANUFACTURE
6. HALLIDAY W2S 72" X 48" HATCH SUPPLIED BY ICAST - TO BE CAST INTO FLAT LID
7. HALLIDAY L1B 4.5' ALUMINUM WALL MOUNT LADDER SUPPLIED BY ICAST
8. JOINT TO BE SEALED WITH CS-102 1" BUTYL
9. VERIFY:  
 -LOCATIONS OF 6" DUCTILE IRON, 4" DUCTILE IRON, & 2" BRASS PIPES  
 -REQUIRED DEPTH OF VAULT  
 -LOCATION OF HATCH

**REVISION INFORMATION**

REV.  DATE:	NO REVISIONS TO DATE



SUBMITTAL DRAWING: 60" X 108" X 54" METER VAULT		
CUSTOMER: WARREN COUNTY WATER DISTRICT		
PROJECT: RV BLUE COMPASS METER VAULT		
STRUCTURE: 60IN X 108IN METER VAULT		
QUOTE/SALES ORDER NO: 25-3663		
CHECKED BY: K. CARDWELL	DRAWN BY: J. Horsley - A	
DATE: 10/17/25	SCALE: NTS	PG. 1 OF 1