

Structure Notes: . 1. (CASTING PROVIDED BY OTHERS) 2. PER ASTM C478 SPECIFICATIONS. 3. CONCRETE = 4,000 PSI AT 28 DAYS. 4. REINFORCING PER ASTM A615 (GRADE 60). - TOP SLAB (As .62) #5 BARS AT 6" C.C.E.W.. - RISER/WALLS (As .36) - FLOOR (As .47) #5 BARS AT 8" C.C.E.W.	STRUCTURE SUMMARY: P5) 24" - CASTING HEIGHT - 4" 0 lb P4) 108" - MH FLAT TOP w/24" ECC Hole - 17" 10472 lb P3) 108" - MH RISER - 54" 16703 lb P2) 108" - MH RISER - 84" 26130 lb P1) 108" - MH BASE - 96" 30589 lb 3) 108" - Conseal CS-102 1.00" 0 lb 1) 24" - Conseal CS-102 1.00" 0 lb 2) Hole - 90 0 lb 4) Hole - 6 0 lb 19) MH Step ML-10-TDS-NCR - 10" 0 lb ----- Structure Total: 83894 lb
---	---

