

Job Name: 26-2310 - 3rd & Madison Townhomes - Ph. 1		Plant: 100	Tech: Jared - F	
Job Location: Nashville, TN 37208		6/16/2026 8:47:40 AM	PC: E. Bradley	
Contractor: Hayes Pipe Supply				
Structure ID: C1 ST-CB				
P2		GRADE RING		
GR28x28x8x3				
P3) 28" x 28" - CASTING HEIGHT - 6"		0 lb	Structure Notes: 1. PER ASTM C913 SPECIFICATIONS. 2. CONCRETE = 4,000 PSI AT 28 DAYS. 3. NO STEPS AND NO INVERT CHANNEL. 4. CASTING SUPPLIED BY OTHERS (JBS 4300 F/G). . REINFORCING PER ASTM A615 (GRADE 60). - WALLS (As .31) #5 BARS AT 12" C.C.E.W. - FLOOR (As .31) #5 BARS AT 12" C.C.E.W.	
P2) 28" x 28" - GRADE RING - 3"		290 lb		
P1) 28" x 28" - BOX BASE 6inW, 6inF - 48"		3913 lb		
2) 28" x 28" - Conseal CS-102 1.00"		0 lb		
1) Hole - 16		0 lb		
1) Hole - 14		0 lb		
Structure Total:		4203 lb		
28" 28" + 0°-				
28" x 28" - GRADE RING - 3" - (P2)				
Coating (Int): Coating (Ext):	Seam Up: Flat Seam Dn: Flat	Wall Thickness: 8"	Height (Ext): 3"	Weight (Net): 290 lb Volume (Net): 0.07cu.yd